

Request for Information

Ref: 00033 FOI

Freedom of Information (Scotland) Act 2002

| | |
|-------------------------|---|
| <p>Questions</p> | <ol style="list-style-type: none"> 1. On how many properties EPS has been installed? 131 Properties have a render based EPS Envirowall EWI system Installed 15 Properties have had a render based Rockshield EWI system Installed. 2. Of the properties which had it installed, how many had (i) fire retardant and (ii) non-fire-retardant EPS installed? All properties have BBA Certified fire-retardant systems installed. 3. How many of those properties EPS been removed from? No properties have had EPS removed. 4. Of the properties which had EPS installed, how many had 6mm or more of render cover installed? All systems installed have 4mm base and 6mm - 8mm topcoat installed. |
| | <p>Please note that this response constitutes full release under the Freedom of Information (Scotland) Act 2002.</p> |

Corporate Manager, Scottish Borders Housing Association, Whinfield Road, Selkirk TD7 4EJ
enquiries@sbha.org.uk; Tel: 01750 72 4444

Scottish Charity Registered No. SC 030751 Registered Society No. 2573R(s) The Scottish Housing Regulator Registered No: 313